

Our Ref: HL/M1304127
Test Report: Report Ref



4th April 2013

Spencer Coatings Ltd.
Blackwell Road,
Huthwaite,
Notts.
NG17 2RL

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

SITE APPLIED PIPE AND FITTINGS COATINGS

5042

Acothane Blue (blue coloured) and Acothane Cream (cream coloured), two pack, solvent free coatings to be used in conjunction with Acothane LV, a two pack, solvent free, polyurethane sealer.

Both the coating and sealer are to be mixed and applied as per manufacturer's instructions.

Acothane DW instructions have reference 06ADW, issue 1 dated July 2012.

Acothane LV instructions have reference 06ALVS (A10), issue 3 dated November 2009.

Acothane LV Sealer to be applied and then cured for 48 hours at 3°C.

Acothane DW to be applied on top of sealer and then cured for 7 days at 3°C.

For use with water up to 23°C.

This material is only approved for the curing conditions that appear on the approval. If the cure conditions are varied from those specified on the approval then the material is not covered by the scope of the approval.

APPROVAL NUMBER: 1301554


APPROVAL HOLDER: SPENCER COATINGS LTD.

The Scheme reserves the right to review approval. This approval is valid between January 2013 and January 2018.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'J. Furnival', with a stylized flourish at the end.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme